



# PhilGEPS

Philippine Government Electronic Procurement System

Central Portal for  
Philippine Government  
Procurement Opportunities

[Help](#)

## Bid Notice Abstract

### Request for Quotation (RFQ)

**Reference Number** 4562094  
**Procuring Entity** BATANES GENERAL HOSPITAL  
**Title** S & D of 40kVa Voltage Stabilizer  
**Area of Delivery** Batanes

<b>Solicitation Number:</b>	RFQ-2017-24	<b>Status</b>	<b>Pending</b>
<b>Trade Agreement:</b>	Implementing Rules and Regulations		
<b>Procurement Mode:</b>	Negotiated Procurement - Small Value Procurement (Sec. 53.9)	<b>Associated Components</b>	2
<b>Classification:</b>	Goods	<b>Bid Supplements</b>	0
<b>Category:</b>	Electrical Supplies		
<b>Approved Budget for the Contract:</b>	PHP 100,000.00	<b>Document Request List</b>	0
<b>Delivery Period:</b>	45 Day/s		
<b>Client Agency:</b>		<b>Date Published</b>	31-May-2017
<b>Contact Person:</b>	Ricardo V Nuñez Administrative Officer V & BAC-Chairman National Road, Bgry, Kayhuvokan Basco Batanes Philippines 3900 63-999-9952283  bgh_bso@yahoo.com	<b>Last Updated / Time</b>	30-May-2017 17:25 PM
		<b>Closing Date / Time</b>	05-Jun-2017 09:00 AM

#### Description

Republic of the Philippines  
Department of Health  
Regional Health Office - 02  
BATANES GENERAL HOSPITAL  
Basco, Batanes  
E-mail Address: bgh\_bso@yahoo.com

REQUEST FOR QUOTATION  
RFQ-2017-24

SUPPLY AND DELIVERY OF 40kVa Voltage Stabilizer

1. The Department of Health, Batanes General Hospital (Procurement under Alternative Method of Procurement - Small Value Procurement) invites local traders/dealers/distributors who can submit the best offer for the Supply and Delivery of 40kVa Voltage Stabilizer. The Approved Budget for the Contract (ABC) to payments under the contract is PhP100,000.00. Interested bidders must comply with the following minimum requirements:

- In the current business for at least three (3) years and still in operation.
- Not blacklisted by any other government office or agency.

c. Has a valid PhilGEPS Certificate.

2. Source of Fund: TrustFund

3. Delivery period shall be within 45 calendar days upon receipt of Purchase Order.

4. For evaluation purposes, prospective bidders are required to submit the following documents:

a. Registration certificate from the Securities and Exchange Commission (SEC), or from Department of Trade and Industry (DTI), or any proof of such registration;


b. Valid Mayor's Permit issued by the city or municipality where the principal place of business of the prospective bidder is located;

c. Duly accomplished Request for Quotation Form.

5. Interested parties are required to submit their sealed price offer/quotation, together with the above-stated documents to:

BGH Bids and Awards Committee  
c/o Ricardo V. Nuñez, Chairman  
National Road, Kayhuvokan  
Basco, Batanes

Deadline for submission of price offer, together with all the required documents, is on  
June 5, 2017 2:00 p.m.

  
RICARDO V. NUÑEZ  
BAC-Chairman  
Batanes General Hospital  
CP # 09999952283

BATANES GENERAL HOSPITAL  
National Road, Kayhuvokan  
Basco, Batanes

Date of Publication: May 31, 2017

**Created by** Ricardo V Nuñez

**Date Created** 30-May-2017

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.

## TECHNICAL SPECIFICATIONS

**Project Title: Supply & Delivery of 40kVA Voltage Stabilizer**

Type or print clearly the SUPPLIER'S technical proposal on the space provided. DO NOT LEAVE ANY BLANKS. A "YES" or "NO" ENTRY WILL NOT BE ACCEPTED. FAILURE TO COMPLY WILL RESULT IN THE REJECTION OF THE BIDDER'S PROPOSAL.

Item No. <b>1</b>	Total Qty : <b>1 unit</b>
Item Description : <b>Voltage Stabilizer, 40kVA</b>	Origin :
Manufacturer :	
Brand/Model :	
<b>PURCHASER'S SPECIFICATIONS</b>	<b>SUPPLIER'S SPECIFICATIONS</b>
<b>Power Supply:</b> 120~270VAC, 3-prong power cord	
<b>Frequency:</b> 60hZ	
<b>Output voltage:</b> 220VAC	
<b>Control:</b> Automatic/Manual. In Case Of Auto Failuer, Output Can Be Increased Or Decreased In Manual Mode	
<b>Phase:</b> Single	
<b>Protection:</b> Low voltage protection; High voltage protection; Overload protection; Short circuit protection; Single phasing preventer	
<b>Panel Control:</b> Input/output select switch; Auto/manual select switch; Increase/decrease switch to control the output voltage in manual mode; Volt adjust to set required output voltage in auto mode	
<b>Panel Indication:</b> Input-ON; Output-ON; Input-LOW; Input-HIGH; Output-CUTOFF	
<b>Standard Requirements:</b> 1. Manuals in English Language 2. Has internationally recognized Compliance and Safety Standards. 3. with FREE five (5) pcs. Fuse	
<b>Warranty:</b> One (1) year	
<b>Note:</b> For purposes of evaluation, the prospective Bidder shall attach a clear photo of the product being offered.	

Bidder Name : \_\_\_\_\_

Signature of Bidder : \_\_\_\_\_

Date : \_\_\_\_\_

R